



NC DEPARTMENT OF
**HEALTH AND
HUMAN SERVICES**

ROY COOPER • Governor
KODY H. KINSLEY • Secretary
MARK BENTON • Chief Deputy Secretary for Health
KELLY KIMPLE • Acting Director, Division of Public Health

December 31, 2024

Theodore Meyers
Tuf-Tite, Inc.
1200 Flex Court
Lake Zurich, IL 60047

Subject: Renewed Effluent Filter and Riser Approvals

Dear Mr. Meyers,

Pursuant to 15A NCAC 18E .1405, Tuf-Tite, Inc. has submitted an application for renewal of your effluent filter and riser approvals, EF-17-R2 and SR-10-R3. The approvals have been renewed.

The enclosed approvals, EF-17-R2 and SR-10-R3, represent the formal status of your approved products in North Carolina.

You have a right to a formal appeal of this decision. To pursue a formal appeal, you must file a petition for a contested case hearing with the Office of Administrative Hearings, 1711 New Hope Church Rd, Raleigh, NC 27609. To get a copy of a petition form, you may write the Office of Administrative Hearings, call the office at 984-236-1850, or download it from the OAH web site at <http://www.ncoah.com/forms.html>. The petition for a contested case hearing must be filed in accordance with the provision of G.S. 130A-24 and 150B-23 and all other applicable provisions of Chapter 150B.

If you wish to pursue a formal appeal, you must file the petition form with the Office of Administrative Hearings within 30 days of the date of this letter, as provided in G.S. 150B-23(f). If you file a petition for a contested case hearing with the Office of Administrative Hearings, you are required by G.S. 150B-23 to serve a copy of your petition on the Office of General Counsel, NC Department of Health and Human Services, 2001 Mail Service Center, Raleigh, NC 27699-2001. The Registered Agent for the Department of Health and Human Services is Julie Cronin.

Local health departments are notified of approved wastewater systems by posting of the approval on the On-Site Water Protection Branch's homepage and by e-mail.

NC DEPARTMENT OF HEALTH AND HUMAN SERVICES • DIVISION OF PUBLIC HEALTH

LOCATION: 5605 Six Forks Road, Building 3, Raleigh, NC 27609
MAILING ADDRESS: 1642 Mail Service Center, Raleigh, NC 27699-1642
www.ncdhhs.gov • TEL: 919-707-5874 • FAX: 919-845-3972

AN EQUAL OPPORTUNITY / AFFIRMATIVE ACTION EMPLOYER

Tuf-Tite, Inc
December 31, 2024
Page 2 of 2

Please do not hesitate to contact me at 919-218-2580 or trish.angoli@dhhs.nc.gov if you have any questions pertaining to this approval renewal or if you need further assistance.

Sincerely,

A handwritten signature in black ink, appearing to be 'Tricia Angoli', written over a large, light-colored oval shape.

Tricia Angoli, PE
On-Site Wastewater Engineering

Enclosures

cc: OSWP Staff
Local Health Departments

**NORTH CAROLINA DEPARTMENT OF HEALTH AND HUMAN SERVICES
DIVISION OF PUBLIC HEALTH
ENVIRONMENTAL HEALTH SECTION
ON-SITE WATER PROTECTION BRANCH**

SEPTIC TANK EFFLUENT FILTER APPROVAL

Septic Tank Effluent Filter Approval Number: EF-17-R2

Issued To: Tuf-Tite, Inc
1200 Flex Court
Lake Zurich, IL 60047
www.tuf-tite.com

Contact: Theodore Meyers
847-550-1011

For: Septic Tank Effluent Filter Models EF-4 and EF-6 and Filter Housings TB-4 and TB-6

Date: October 25, 1999
October 20, 2003 Addition of Model EF-6 and TB-6
December 31, 2024 Updated for 18E and renewed for 2025

In accordance with G.S. 130A-335 and 130A-335.1 and 15A NCAC 18E .1404 and .1405, an application by Tuf-Tite, Inc, for renewal of the approval for septic tank effluent filters has been reviewed and approved when the following conditions are met.

I. Description

- a. Effluent filters shall be designed and manufactured in accordance with the plans, specifications and documents submitted by the manufacturer with the application.
- b. Effluent filters shall meet the specifications in Table I.

Table I. Approved Filter Model Specifications						
Filter Models	Size	Support Case ¹	Case Dimensions		Min. Tank Liquid Depth Required	Min. Access Opening Size ³
			Above Liquid Level	Below Liquid Level ²		
EF-4	4" dia. x 18"	4" PVC Tee or TB-4 Filter Housing ²	6"	12-inch minimum ³	36"	15 x 15 in. or 17 in. dia. or equal
Dual EF-4	2 filters, each 4" dia. x 18"	2 cases, 4" PVC Cross, + 2-4" PVC Tees or 2-TB-4 Filter Housings ²	6"	12-inch minimum ³	36"	17 x 17 in. or 17 in. dia. or equal
EF-6	6" dia. x 18"	TB-6 Filter Housing ²	6"	12-inch minimum ³	36"	15 x 15 in. or 17 in. dia. or equal
Dual EF-6	2 filters, each 6" dia. x 18"	2 cases, 4" PVC Cross, + 2-TB-4 Filter Housings ²	6"	12-inch minimum ³	36"	18 x 18 in. or 20 in. dia. or equal

Notes:

1. Support case provided by the septic tank manufacturer.
2. Optional TB-4 filter housing for EF-4 filters and required TB-6 filter housing for EF-6 filters provided to tank manufacturer by filter manufacturer.
3. Other minimum opening sizes or configurations proposed by the septic tank manufacturer shall be approved by the State on a case-by-case basis if documentation is provided showing both adequate access is provided for filter maintenance and for pumping the tank outlet compartment.

II. Sizing

The approved effluent filters may be used in approved septic tanks. The approved flow capacities are shown in Table II. The effluent filter sizing must be compatible with the design daily flow and the minimum septic tank size in accordance with 15A NCAC 18E .0801.

Filter Model	Maximum Design Flow (gallons/day)
EF-4	800
Dual EF-4	1,600
EF-6	1,500
Dual EF-6	3,000

Notes:

1. Sizing based on domestic strength effluent in accordance with 15A NCAC 18E .0402(a), Table III.
2. If the effluent filters are used in a system with a design daily flow greater than 3,000 gallons/day, the design requires a Professional Engineer and a project specific approval.


III. Installation

The effluent filters and effluent filter support case shall be assembled and installed in accordance with the filter manufacturer's specifications and applicable rules. The filter case shall be located in such a manner that the filter can be readily accessible by the operator from the access opening and removable by hand from finished grade. The access opening shall also provide enough room to allow for pumping of the tank compartment. An access device manufactured by Tuf-Tite, Inc, shall be provided whenever the tank is installed with the filter handle deeper than 18-inches below the access opening or more than 18-inches below finished grade.

IV. Operation and maintenance

Effluent filters shall be used and maintained in accordance with the effluent filter manufacturer's specifications and applicable laws and rules. Manufacturer-specified procedures shall be followed to minimize the bypass of unfiltered effluent while the filter is being removed when servicing is needed. Tuf-Tite, Inc, has available for purchase a slotted sleeve removal tool that prevents material from leaving the outlet tee while the filter is being replaced. Upon removal, effluent filters shall either be replaced with a new effluent filter and the used effluent filter disposed of in an approved disposal method, or debris shall be washed off the effluent filter into the septic tank and the effluent filter placed back into service.

Approved by:  _____

Date:  _____

**NORTH CAROLINA DEPARTMENT OF HEALTH AND HUMAN SERVICES
DIVISION OF PUBLIC HEALTH
ENVIRONMENTAL HEALTH SECTION
ON-SITE WATER PROTECTION BRANCH**

SEPTIC AND PUMP TANK RISER APPROVAL
--

Septic Tank and Pump Tank Riser Assembly Approval: SR-10-R3

Issued To: Tuf-Tite, Inc
1200 Flex Court
Lake Zurich, IL 60047
www.tuf-tite.com

Contact: Theodore Meyers
847-550-1011

For: HDPE 20-inch and 24-inch Septic Tank and 24-inch Pump Tank Riser Assemblies

Date: October 8, 1999
July 24, 2003 Addition of Pump Tank Riser and Riser Safety Pan
September 30, 2020 Addition of Internal Safety Lid
December 31, 2024 Updated for 18E and renewed for 2025

In accordance with G.S. 130A-335 and 130A-335.1 and 15A NCAC 18E .1404 and .1405, an application by Tuf-Tite, Inc, for renewal of their approval for septic tank and pump tank risers has been reviewed and approved when the following conditions are met.

- I. Description
 - a. Risers and associated accessories shall be designed and manufactured in accordance with plans, specifications, and supporting documents provided by the manufacturer in their application for approval submitted to the On-Site Water Protection Branch.
 - b. Approved risers and accessories shall meet the specifications outlined in Table 1.

Table 1. Riser Model Specifications			
Riser Models	Inside diameter	Min. Tank Top Width Required	Riser Installation Limitations ^{1,2}
20" HDPE round riser (6" high stackable sections) and lid assembly with tamper-resistant stainless-steel screws and one of the following: 5" riser safety pan ³ and internal concrete plug; riser section with the internal safety lid ⁴ ; or the internal concrete plug and the internal safety lid	20"	28"	Septic tank – must be installed 6" below finished grade or at least 3" above finished grade

24" HDPE round riser (6" high stackable sections) and lid assembly with tamper-resistant stainless-steel screws and one of the following; 5" riser safety pan ³ and internal concrete plug; riser section with the internal safety lid ⁴ ; or the internal concrete plug and the internal safety lid	24"	32"	Septic tank – must be installed 6" below finished grade or at least 3" above finished grade Pump tank ⁵ – must be installed at least 6" above finished grade
--	-----	-----	--

Notes:

1. Riser systems must not be subjected to vehicular or other excessive live loads or buried deeper than three feet below finished grade.
2. Mechanisms to prevent accidental entry to the tank include use of tamper-resistant screws (No. 2 square notched head, or approved equal), at least two horizontal safety screws, and the internal concrete plug or riser section with the internal safety lid. A septic tank can use both the riser safety pan with an internal concrete plug and the riser section with an internal safety lid.
3. The riser safety pan provides support for the internal concrete plug. Pans are five inches high, with internal diameters of 20 to 24 inches for 24-inch pans and 17 to 20 inches for 20-inch pans. Pans also may serve as separate riser sections for septic tanks. For pump tanks, use only a single riser safety pan or riser section with internal safety lid located at the top of the riser just below, and attached to, the riser. Make certain the plug handle doesn't prevent the lid from being properly secured on top of the riser safety pan when used.
4. The internal safety lid is designed for a dead load of over 500 pounds. The internal safety lid shall be secured to the riser with four tamper-resistant stainless-steel screws. For extra security, the internal safety lid underside can be filled with concrete.
5. Pump tank riser sections include pre-formed bosses through which wire conduit and pump discharge pipe can be installed.


II. Installation

- a. The risers shall be assembled and installed in accordance with the manufacturer's specifications, applicable rules, and approval conditions.
- b. For new septic tank installations, a Tuf-Tite initial riser section or riser safety pan section shall be cast into the tank during tank construction. One of the following installation methods shall be used.
 1. Cast-in-place with internal collar: The bottom riser section shall be cast in the concrete with the riser lid secured in place, retaining a concrete inner collar around the internal circumference of the riser. A 17-inch diameter opening should be formed at a minimum. The riser shall be placed in the tank top mold in such a manner that 1½ inches of concrete shall be below the riser bottom. A tapered concrete support collar shall surround the riser, beginning at a height of four inches above the bottom of the riser and tapering away from the riser on a projected slope of 1:8. Four No. 3 rebars (one on each side of the riser, making a picture frame) shall be placed one inch away extending three to six inches beyond the riser; or
 2. Cast in Place with Riser Safety Pan: The riser safety pan section shall be cast into the top of the tank, with a pre-manufactured concrete plug in place. When the tank top slab is less than four inches thick, a concrete fillet shall be provided around the riser so that the total thickness of the concrete slab will be at least four inches around the riser, tapering away from the riser on a projected slope of 1:8. The support collar shall be constructed so as to not interfere with the installation of a riser lid or riser section onto the riser safety pan. Four No. 3 rebars (one on each side of the riser, making a picture frame) shall be placed one inch away extending three to six inches beyond the riser.
- c. For new pump tank installations, one of the following methods shall be used.
 1. A 24-inch Tuf-Tite® riser section (seven inches high) shall be cast into the tank fully penetrating the tank top. A riser safety pan shall **not** be cast into the pump tank top. When the top tank slab is less than four inches thick, a concrete fillet shall be provided around the riser so that the total thickness of the concrete slab will be at least four inches around the riser, tapering away from the riser on a projected slope of 1:8. Four No. 3 rebar (one on each side of the riser, making a picture frame) shall be placed one inch away from the opening extending three to six inches beyond the riser.
 2. The top (highest) riser section shall be a riser safety pan that can accommodate an internal concrete plug or a riser section with an internal safety lid. No other riser safety pans shall be used in the riser. The riser safety pan or riser section with internal safety lid shall be secured to the riser section below with preformed 5/16-inch butyl rope in accordance with ASTM C-990 and secured with six No. 10 x 1-

- 3/4 inch stainless steel sheet metal screws provided by the riser manufacturer. The riser safety pan, if necessary, shall be removable to facilitate access to the pump and floats.
3. Wire connections and the pump discharge pipe shall go through bulkhead connectors or Tuf-Tite RS-2 synthetic rubber seals made of Santoprene to make a secure watertight connection. The riser manufacturer shall provide the seals or connectors. The seals or connectors shall be installed through holes drilled by the installer into the pre-formed bosses provided in the risers. For systems where the discharge pipe is designed to pass through the riser, make certain the pump disconnect is reachable from the top of the riser, 18 inches maximum below the riser lid, and the pipe shall remain below the local frost line.
 - d. Riser retrofit installations may be approved by the local health department on a case-by-case basis when used with an existing septic tank or pump tank. Risers shall be attached in a structurally sound, watertight fashion in accordance with the riser manufacturer's specifications.
 - e. Riser sections must be sealed together with preformed 5/16-inch butyl rope meeting the performance standards of ASTM C-990 and secured with six number 10 x 1 3/4-inch stainless-steel sheet metal screws provided by the riser manufacturer. The riser lid must have a watertight compressible polyurethane gasket and be screwed down with at least six tamper-resistant stainless-steel screws, No. 2 square-notched screws or approved alternate. At least two horizontal safety screws shall be provided and located as indicated on top of the riser lid.
 - f. In addition to the proposed tamper-resistant stainless-steel fasteners provided by the riser manufacturer, the septic tank and pump tank manufacturer shall provide an internal, secondary concrete lid to prevent accidental entry to the tank when using these risers. The lid shall be circular, at least 2-1/2-inches thick, reinforced, and include a handle in accordance with 15A NCAC 18E .1410(b)(10). For septic tanks, the concrete lid shall either rest on the internal concrete collar or riser safety pan, as applicable. For risers deeper than 18 inches, a riser safety pan to support the internal concrete plug or riser section with internal safety lid shall be located no deeper than 18 inches below the top of the riser. The effluent filter model utilized in conjunction with this riser assembly shall not be interfered with by the internal concrete plug or internal safety lid. For pump tanks, the riser safety pan and internal concrete lid or riser section with internal safety lid shall be located immediately beneath the riser lid. The internal lid must be readily removable from the riser from above grade.
 - g. This riser system must not be installed in areas subjected to vehicular traffic, or where the tank shall be buried more than three feet below finished grade.

Approved by: _____

Date: _____



12/31/2024

